

# 2025 Water Quality Report for FORD RIVER TOWNSHIP

Water Supply Serial Number: **2350**

This report covers the drinking water quality for Ford River Township, for the calendar year 2025. This information is a snapshot of the quality of the water that we provided to you in 2025. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards.

Your water comes from two groundwater wells, **#2** drilled in 1972 at 370' in depth, and **#3** drilled in 1992 at 665 feet in depth. The State performed an assessment of our source water in 2003 to determine the susceptibility or the relative potential of contamination. The susceptibility rating is on a seven-tiered scale from "very low" to "very high" based on geologic sensitivity, well construction, water chemistry, and contamination sources. The susceptibility of well #2 and #3 are rated very low, and well #1 was abandoned in 2011 based off the susceptibility being rated very high.

There are no significant sources of contamination in our water supply.


*For more information about the contents of this report, you can contact Troy Rodman at [water@fordriver.org](mailto:water@fordriver.org), or the township hall 906-786-8532*

- **Contaminants and their presence in water:** Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **EPA's Safe Drinking Water Hotline (800-426-4791)**.
- **Vulnerability of sub-populations:** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/CDC for Disease control guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).
- **Sources of drinking water:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water comes from wells, as water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

## **Contaminants that may be present in source water include:**

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.
- **Radioactive contaminants**, which are naturally occurring or be the result of oil and gas production and mining activities.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can, also, come from gas stations, urban stormwater runoff, and septic systems.

*In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establishes for contaminants in bottled water which provide the same protection for public health.*



## Ford River Water Quality Data

The table below lists all the drinking water contaminants that we detected during the 2025 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2025. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All the data is representative of the water quality, but some are more than one year old.

### Terms and abbreviations used below:

- Maximum Contaminant Level Goal (MCLG)  
The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Contaminant Level (MCL):  
The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Residual Disinfectant Level (MRDL):  
The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Maximum Residual Disinfectant Level Goal (MRDLG):  
The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Treatment Technique (TT):  
A required process intended to reduce the level of contaminant in drinking water.
- MC:  
Many compounds tested in this group, each have their own EPA assigned MCL and MCLG.
- Action Level (AL):  
The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
  
- N/A: Not applicable
- ND: not detectable at testing limit
- ppm: parts per million or milligrams per liter
- ppb: parts per billion or micrograms per liter
- ppt: parts per trillion or nanograms per liter
- pCi/l: picocuries per liter (a measure of radioactivity)

1 Monitoring Data for Regulated Contaminants

Regulated Contaminant	MCL, TT, or MRDL	MCLG or MRDLG	Level Detected	Year Sampled	Violation Yes/No	Typical Source of Contaminant
Barium (ppm)	2	2	0.033	2019	No	Discharge of drilling wastes; Discharge of metal refineries; Erosion of natural deposits
Cyanide	0.2	0.2	ND	2019	No	Used in electroplating, steel processing, plastics, synthetic fabrics, fertilizer production; also, from improper waste disposal
Nitrate/Nitrite-N (dw) (ppm)	10	10	<0.020	2025	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Fluoride (ppm)	4	4	0.78	2025	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Sodium <sup>1</sup> (ppm)	N/A	N/A	33	2025	No	Erosion of natural deposits
Alpha emitters (pCi/L)	15	0	2.17	2021	No	Erosion of natural deposits
Combined radium (pCi/L)	5	0	4.29	2024	No	Erosion of natural deposits
Total Coliform	TT	0	0	Monthly	No	Naturally present in the environment
E. coli in the distribution system (positive samples)	See E. coli note <sup>2</sup>	0	0	Monthly	No	Human and animal fecal waste
Volatile Organic Compounds (ppb)	MC	MC	0	2025	No	Enter the environment when used to make plastics, dyes, rubbers, polishes, solvents, crude oil, insecticides, inks, varnishes, paints
SOC's (Pest, Herb, Carb. All) ppb	MC	MC	0	2025	No	Pesticides, Herbicides, Carbamates

<sup>1</sup> Sodium is not a regulated contaminant.

<sup>2</sup> *E. coli* MCL violation occurs if: (1) routine and repeat samples are total coliform-positive and either is *E. coli*-positive, or (2) the supply fails to take all required repeat samples following *E. coli*-positive routine sample, or (3) the supply fails to analyze total coliform-positive repeat sample for *E. coli*.

Regulated Contaminant	MCL, TT, or MRDL	MCLG or MRDLG	Level Detected	Range	Year Sampled	Violation Yes/No	Typical Source of Contaminant
Hexafluoropropylene oxide dimer acid (HFPO-DA) (ppt)	370	N/A	ND	<2	2025	No	Discharge and waste from industrial facilities utilizing the Gen X chemical process
Perfluorobutane sulfonic acid (PFBS) (ppt)	420	N/A	ND	<2	2025	No	Discharge and waste from industrial facilities; stain-resistant treatments
Perfluorohexane sulfonic acid (PFHxS) (ppt)	51	N/A	ND	<2	2025	No	Firefighting foam; discharge and waste from industrial facilities
Perfluorohexanoic acid (PFHxA) (ppt)	400,000	N/A	ND	<2	2025	No	Firefighting foam; discharge and waste from industrial facilities
Perfluorononanoic acid (PFNA) (ppt)	6	N/A	ND	<2	2025	No	Discharge and waste from industrial facilities; breakdown of precursor compounds
Perfluorooctane sulfonic acid (PFOS) (ppt)	16	N/A	ND	<2	2025	No	Firefighting foam; discharge from electroplating facilities; discharge and waste from industrial facilities
Perfluorooctanoic acid (PFOA) (ppt)	8	N/A	ND	<2	2025	No	Discharge and waste from industrial facilities; stain-resistant treatments
Inorganic Contaminant Subject to Action Levels (AL)	Action Level	MCLG	Your water <sup>3</sup>	Range	Year Sampled	Number of Samples Above AL	Typical Source of Contaminant
Lead (ppb)	12	0	0.0	0 ppb-0 ppb	2024	0	Lead service lines, corrosion of household plumbing including fittings and fixtures; Erosion of natural deposits
Copper (ppm)	1.3	1.3	0.0	0 ppm-0 ppm	2024	0	Corrosion of household plumbing systems; Erosion of natural deposits

<sup>3</sup> Ninety (90) percent of the samples collected were at or below the level reported for our water.

**Information about lead:**

Lead can cause serious health effects in people of all ages, especially pregnant women, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and within home plumbing. Ford River Township is responsible for providing high quality drinking water and removing known lead piping but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for at least 5 minutes to flush water from both your home plumbing and the lead service line. If you are concerned about lead in your water and wish to have your water tested, contact **Ford River Township (906-399-6411)** for available resources. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>

**Service Material:**

**Our water supply has 0 full lead service lines, but there are galvanized lines connected to lead goosenecks present.**

The system has 133 copper/plastic services, 19 galvanized services, and 51 unknowns for a total of 203 connections.

Monitoring and Reporting to the Department of Environment, Great Lakes, and Energy (EGLE) Requirements: The State of Michigan and the U.S. EPA require us to test our water on a regular basis to ensure its safety. We met all the monitoring and reporting requirements for 2025.

We will update this report annually and will keep you informed of any problems that may occur throughout the year, as they happen. This report will also be posted online at [fordriver.org](http://fordriver.org)

We invite public participation in decisions that affect drinking water quality. The Township Board Meeting is scheduled the second Monday of each month at 7:00 pm E.T. For more information about safe drinking water, visit the U.S. EPA at <http://www.epa.gov/safewater>.

For more information about your water, please contact: **Troy Rodman at 906-241-4346, or [water@fordriver.org](mailto:water@fordriver.org)**

**VIOLATION NOTICE**

1. Reporting for Nitrate, Volatile Organic Chemicals (VOCs), Synthetic Organic Chemicals (SOCs), and Per- and Polyfluoroalkyl Substances (PFAS). *Michigan Safe Drinking Water Act 1976, PA 399: R 325.10743, Required reporting to the department of the 1979 Administrative Code.*
  - A. During the 2025 Monitoring Period – The Township collected all annual samples within the month of August 2025 and reported results to an EGLE representative with a typo in an email address on September 15, 2025. This reporting issue was not caught until November 5, 2025, which is after the reporting due date of September 30, 2025. The sample results were correctly sent out on November 6, 2025, and no further sampling was required